

Source Water Entering Temp = 90°F	HEATING MODE										COOLING MODE				
	Units	R-410A					R-134a					R-410A	R-134a	Units	
	Building Water Entering Temp	°F					100	110	120	130	140	55	55	°F	Building Water Entering Temp
Building Water Leaving Temp	°F					110	120	130	140	150	45	45	°F	Building Water Leaving Temp	
Heating Capacity	MBTUH					592.7	567.5	386.3	373.1	359.9	359.8	241.5	MBTUH	Cooling Capacity	
Condenser Water Flow	GPM					118.5	113.5	77.3	74.6	72.0	72.0	48.3	GPM	Evaporator Water Flow	
Evaporator Load	MBTUH					492.0	454.6	305.3	282.5	258.6	449.2	298.7	MBTUH	Condenser Load	
Evaporator Water Flow	GPM					98.4	90.9	61.1	56.5	51.7	89.8	59.7	GPM	Condenser Water Flow	
Power Input	kW					29.5	33.1	23.7	26.6	29.7	26.2	16.8	kW	Power Input	
COP	-					5.88	5.03	4.77	4.12	3.55	13.74	14.40	-	EER	
Source Water Leaving Temp	°F					80	80	80	80	80	100	100	°F	Source Water Leaving Temp	

Source Water Entering Temp = 80°F	HEATING MODE										COOLING MODE				
	Units	R-410A					R-134a					R-410A	R-134a	Units	
	Building Water Entering Temp	°F					90	100	110	120	130	140	55	55	°F
Building Water Leaving Temp	°F					100	110	120	130	140	150	45	45	°F	Building Water Leaving Temp
Heating Capacity	MBTUH					617.6	592.7	567.5	386.3	373.1	359.9	385.3	254.4	MBTUH	Cooling Capacity
Condenser Water Flow	GPM					123.5	118.5	113.5	77.3	74.6	72.0	77.1	50.9	GPM	Evaporator Water Flow
Evaporator Load	MBTUH					527.6	492.0	454.6	305.3	282.5	258.6	464.8	305.9	MBTUH	Condenser Load
Evaporator Water Flow	GPM					105.5	98.4	90.9	61.1	56.5	51.7	93.0	61.2	GPM	Condenser Water Flow
Power Input	kW					26.3	29.5	33.1	23.7	26.6	29.7	23.3	15.1	kW	Power Input
COP	-					6.87	5.88	5.03	4.77	4.12	3.55	16.54	16.87	-	EER
Source Water Leaving Temp	°F					70	70	70	70	70	70	90	90	°F	Source Water Leaving Temp

Source Water Entering Temp = 70°F	HEATING MODE										COOLING MODE					
	Units	R-410A					R-134a					R-410A	R-134a	Units		
	Building Water Entering Temp	°F					80	90	100	110	120	130	140	55	55	°F
Building Water Leaving Temp	°F					90	100	110	120	130	140	150	45	45	°F	Building Water Leaving Temp
Heating Capacity	MBTUH					592.5	570.7	548.4	525.8	355.8	344.3	332.8	410.3	265.3	MBTUH	Cooling Capacity
Condenser Water Flow	GPM					118.5	114.1	109.7	105.2	71.2	68.9	66.6	82.1	53.1	GPM	Evaporator Water Flow
Evaporator Load	MBTUH					512.9	481.0	447.9	413.2	275.1	254.0	232.0	480.1	312.2	MBTUH	Condenser Load
Evaporator Water Flow	GPM					102.6	96.2	89.6	82.6	55.0	50.8	46.4	96.0	62.4	GPM	Condenser Water Flow
Power Input	kW					23.3	26.3	29.4	33.0	23.7	26.5	29.6	20.4	13.7	kW	Power Input
COP	-					7.44	6.36	5.46	4.67	4.41	3.81	3.30	20.08	19.30	-	EER
Source Water Leaving Temp	°F					60	60	60	60	60	60	60	80	80	°F	Source Water Leaving Temp

Source Water Entering Temp = 60°F	HEATING MODE										COOLING MODE						
	Units	R-410A					R-134a					R-410A	R-134a	Units			
	Building Water Entering Temp	°F					70	80	90	100	110	120	130	140			°F
Building Water Leaving Temp	°F					80	90	100	110	120	130	140	150			°F	Building Water Leaving Temp
Heating Capacity	MBTUH					521.3	504.3	486.7	468.9	451.3	301.2	292.8	284.7			MBTUH	Cooling Capacity
Condenser Water Flow	GPM					104.3	100.9	97.3	93.8	90.3	60.2	58.6	56.9			GPM	Evaporator Water Flow
Evaporator Load	MBTUH					451.6	424.8	397.2	368.7	339.0	221.2	203.4	184.8			MBTUH	Condenser Load
Evaporator Water Flow	GPM					90.3	85.0	79.4	73.7	67.8	44.2	40.7	37.0			GPM	Condenser Water Flow
Power Input	kW					20.4	23.3	26.2	29.3	32.9	23.4	26.2	29.2			kW	Power Input
COP	-					7.48	6.34	5.44	4.68	4.02	3.77	3.28	2.85			-	EER
Source Water Leaving Temp	°F					50	50	50	50	50	50	50	50			°F	Source Water Leaving Temp

Source Water Entering Temp = 50°F	HEATING MODE										COOLING MODE							
	Units	R-410A					R-134a					R-410A	R-134a	Units				
	Building Water Entering Temp	°F					60	70	80	90	100	110	120	130	140			°F
Building Water Leaving Temp	°F					70	80	90	100	110	120	130	140	150			°F	Building Water Leaving Temp
Heating Capacity	MBTUH					454.7	441.9	428.3	414.4	400.7	387.6	254.6	249.0	243.8			MBTUH	Cooling Capacity
Condenser Water Flow	GPM					90.9	88.4	85.7	82.9	80.1	77.5	50.9	49.8	48.8			GPM	Evaporator Water Flow
Evaporator Load	MBTUH					395.2	372.1	348.8	325.1	300.7	275.2	175.5	160.6	145.1			MBTUH	Condenser Load
Evaporator Water Flow	GPM					79.0	74.4	69.8	65.0	60.1	55.0	35.1	32.1	29.0			GPM	Condenser Water Flow
Power Input	kW					17.5	20.4	23.3	26.2	29.3	33.0	23.2	25.9	28.9			kW	Power Input
COP	-					7.63	6.33	5.39	4.64	4.00	3.45	3.22	2.82	2.47			-	EER
Source Water Leaving Temp	°F					40	40	40	40	40	40	40	40	40			°F	Source Water Leaving Temp

Source Water Entering Temp = 40°F	HEATING MODE										COOLING MODE							
	Units	R-410A					R-134a					R-410A	R-134a	Units				
	Building Water Entering Temp	°F					60	70	80	90	100	110	120	130				°F
Building Water Leaving Temp	°F					70	80	90	100	110	120	130	140				°F	Building Water Leaving Temp
Heating Capacity	MBTUH					384.0	373.8	363.1	352.6	342.5	333.4	215.0	211.9			MBTUH	Cooling Capacity	
Condenser Water Flow	GPM					76.8	74.8	72.6	70.5	68.5	66.7	43.0	42.4			GPM	Evaporator Water Flow	
Evaporator Load	MBTUH					324.2	304.0	283.8	263.3	242.3	220.6	136.9	124.6			MBTUH	Condenser Load	
Evaporator Water Flow	GPM					64.8	60.8	56.8	52.7	48.5	44.1	27.4	24.9			GPM	Condenser Water Flow	
Power Input	kW					17.5	20.4	23.3	26.2	29.4	33.1	22.9	25.6			kW	Power Input	
COP	-					6.43	5.36	4.58	3.95	3.42	2.95	2.75	2.43			-	EER	
Source Water Leaving Temp	°F					30	30	30	30	30	30	30	30			°F	Source Water Leaving Temp	

Note: In View of Continuous Product Improvements, design and specification are subject to change without notice. EEE can accept no responsibility for possible errors in catalogues, brochures and other printed material.



ENVIRONMENTALLY ENGINEERED EQUIPMENT, INC.

Water-to-Water Heat Pumps DS 30 Data Sheet

