



Compressor	HP	200				240			
		208-230 V		460 V		208-230 V		460 V	
Voltage	V/3/60Hz	410A	134a	410A	134a	410A	134a	410A	134a
Refrigerant		410A	134a	410A	134a	410A	134a	410A	134a
RLA	Amps	94.3	71.5	46.4	39.6	107.1	N/A	56.4	44.0
LRA	Amps	560	560	260	220	680	N/A	320	320
MCA	Amps	778.0	589.9	382.8	326.7	883.6	N/A	352.5	275.0
MOCP	Amps	943.0	715.0	464.0	396.0	1071.0	N/A	423.0	330.0
Dry Weight	lbs	5900				6630			

Note: In View of Continuous Product Improvements, design and specification are subject to change without notice. HHS can accept no responsibility for possible errors in catalogues, brochures and other printed material.

Customer:
Project:
Sales Rep:
Date: AUGUST 2008 Brochure No 801
COPYRIGHT 2011 HHS. INC. ALL RIGHTS RESERVED.

H H Systems, INC
SERIES: ES 200/240
Water-to-Water Heat Pumps

Source Water Entering Temp = 90°F	HEATING MODE										COOLING MODE				
	Units	R-410A					R-134a					R-410A	R-134a	Units	
	Building Water Entering Temp	°F					100	110	120	130	140	55	55	°F	Building Water Entering Temp
Building Water Leaving Temp	°F					110	120	130	140	150	45	45	°F	Building Water Leaving Temp	
Heating Capacity	MBTUH					4102.9	3915.7	2613.8	2530.0	2449.5	2499.1	1603.9	MBTUH	Cooling Capacity	
Condenser Water Flow	GPM					820.6	783.1	522.8	506.0	489.9	499.8	320.8	GPM	Evaporator Water Flow	
Evaporator Load	MBTUH					3,398.1	3,130.3	2037.4	1890.8	1741.6	3128.1	2010.3	MBTUH	Condenser Load	
Evaporator Water Flow	GPM					679.6	626.1	407.5	378.2	348.3	625.6	402.1	GPM	Condenser Water Flow	
Power Input	kW					206.5	230.1	168.9	187.3	207.4	184.3	119.1	kW	Power Input	
COP	-					5.82	4.99	4.53	3.96	3.46	13.56	13.47	-	EER	
Source Water Leaving Temp	°F					80	80	80	80	80	100	100	°F	Source Water Leaving Temp	

Source Water Entering Temp = 80°F	HEATING MODE										COOLING MODE				
	Units	R-410A					R-134a					R-410A	R-134a	Units	
	Building Water Entering Temp	°F					90	100	110	120	130	140	55	55	°F
Building Water Leaving Temp	°F					100	110	120	130	140	150	45	45	°F	Building Water Leaving Temp
Heating Capacity	MBTUH					4282.4	4102.9	3915.7	2613.8	2530.0	2449.5	2666.6	1698.5	MBTUH	Cooling Capacity
Condenser Water Flow	GPM					856.5	820.6	783.1	522.8	506.0	489.9	533.3	339.7	GPM	Evaporator Water Flow
Evaporator Load	MBTUH					3,647.4	3,398.1	3,130.3	2037.4	1890.8	1741.6	3,232.0	2,062.7	MBTUH	Condenser Load
Evaporator Water Flow	GPM					729.5	679.6	626.1	407.5	378.2	348.3	646.4	412.5	GPM	Condenser Water Flow
Power Input	kW					186.0	206.5	230.1	168.9	187.3	207.4	165.7	106.7	kW	Power Input
COP	-					6.74	5.82	4.99	4.53	3.96	3.46	16.10	15.92	-	EER
Source Water Leaving Temp	°F					70	70	70	70	70	70	90	90	°F	Source Water Leaving Temp

Source Water Entering Temp = 70°F	HEATING MODE										COOLING MODE					
	Units	R-410A					R-134a					R-410A	R-134a	Units		
	Building Water Entering Temp	°F					80	90	100	110	120	130	140	55	55	°F
Building Water Leaving Temp	°F					90	100	110	120	130	140	150	45	45	°F	Building Water Leaving Temp
Heating Capacity	MBTUH					4114.1	3962.2	3802.1	3635.5	2402.6	2330.3	2261.6	2820.7	1781.6	MBTUH	Cooling Capacity
Condenser Water Flow	GPM					822.8	792.4	760.4	727.1	480.5	466.1	452.3	564.1	356.3	GPM	Evaporator Water Flow
Evaporator Load	MBTUH					3543.0	3329.2	3098.3	2850.4	1830.5	1696.1	1559.4	3329.5	2110.7	MBTUH	Condenser Load
Evaporator Water Flow	GPM					708.6	665.8	619.7	570.1	366.1	339.2	311.9	665.9	422.1	GPM	Condenser Water Flow
Power Input	kW					167.4	185.5	206.2	230.0	167.6	185.8	205.8	149.1	96.4	kW	Power Input
COP	-					7.20	6.26	5.40	4.63	4.20	3.67	3.22	18.92	18.48	-	EER
Source Water Leaving Temp	°F					60	60	60	60	60	60	60	80	80	°F	Source Water Leaving Temp

Source Water Entering Temp = 60°F	HEATING MODE										COOLING MODE						
	Units	R-410A					R-134a					R-410A	R-134a	Units			
	Building Water Entering Temp	°F					70	80	90	100	110	120	130	140			°F
Building Water Leaving Temp	°F					80	90	100	110	120	130	140	150			°F	Building Water Leaving Temp
Heating Capacity	MBTUH					3616.1	3504.9	3386.1	3261.5	3132.7	2029.3	1978.1	1931.0			MBTUH	Cooling Capacity
Condenser Water Flow	GPM					723.2	701.0	677.2	652.3	626.5	405.9	395.6	386.2			GPM	Evaporator Water Flow
Evaporator Load	MBTUH					3105.3	2937.9	2755.9	2559.3	2348.2	1466.9	1354.9	1241.3			MBTUH	Condenser Load
Evaporator Water Flow	GPM					621.1	587.6	551.2	511.9	469.6	293.4	271.0	248.3			GPM	Condenser Water Flow
Power Input	kW					149.7	166.1	184.6	205.7	229.9	164.8	182.6	202.1			kW	Power Input
COP	-					7.08	6.18	5.37	4.64	3.99	3.61	3.17	2.80			-	EER
Source Water Leaving Temp	°F					50	50	50	50	50	50	50	50			°F	Source Water Leaving Temp

Source Water Entering Temp = 50°F	HEATING MODE										COOLING MODE							
	Units	R-410A					R-134a					R-410A	R-134a	Units				
	Building Water Entering Temp	°F					60	70	80	90	100	110	120	130	140			°F
Building Water Leaving Temp	°F					70	80	90	100	110	120	130	140	150			°F	Building Water Leaving Temp
Heating Capacity	MBTUH					3140.9	3063.5	2978.8	2888.8	2795.4	2700.2	1715.1	1682.1	1653.7			MBTUH	Cooling Capacity
Condenser Water Flow	GPM					628.2	612.7	595.8	577.8	559.1	540.0	343.0	336.4	330.7			GPM	Evaporator Water Flow
Evaporator Load	MBTUH					2685.5	2556.4	2414.8	2260.8	2094.7	1916.6	1163.8	1071.8	978.9			MBTUH	Condenser Load
Evaporator Water Flow	GPM					537.1	511.3	483.0	452.2	418.9	383.3	232.8	214.4	195.8			GPM	Condenser Water Flow
Power Input	kW					133.4	148.6	165.3	184.0	205.3	229.6	161.5	178.8	197.7			kW	Power Input
COP	-					6.90	6.04	5.28	4.60	3.99	3.45	3.11	2.76	2.45			-	EER
Source Water Leaving Temp	°F					40	40	40	40	40	40	40	40	40			°F	Source Water Leaving Temp

Source Water Entering Temp = 40°F	HEATING MODE										COOLING MODE							
	Units	R-410A					R-134a					R-410A	R-134a	Units				
	Building Water Entering Temp	°F					60	70	80	90	100	110	120	130	140			°F
Building Water Leaving Temp	°F					70	80	90	100	110	120	130	140			°F	Building Water Leaving Temp	
Heating Capacity	MBTUH					2646.1	2589.0	2526.8	2461.5	2397.2	2325.1	1451.3	1433.9			MBTUH	Cooling Capacity	
Condenser Water Flow	GPM					529.2	517.8	505.4	492.3	479.4	465.0	290.3	286.8			GPM	Evaporator Water Flow	
Evaporator Load	MBTUH					2194.1	2084.8	1965.2	1835.8	1696.6	1547.8	913.6	839.2			MBTUH	Condenser Load	
Evaporator Water Flow	GPM					438.8	417.0	393.0	367.2	339.3	309.6	182.7	167.8			GPM	Condenser Water Flow	
Power Input	kW					132.4	147.7	164.5	183.3	205.3	227.8	157.5	174.3			kW	Power Input	
COP	-					5.85	5.13	4.50	3.93	3.42	2.99	2.70	2.41			-	EER	
Source Water Leaving Temp	°F					30	30	30	30	30	30	30	30			°F	Source Water Leaving Temp	

Note: In View of Continuous Product Improvements, design and specification are subject to change without notice. HHS can accept no responsibility for possible errors in catalogues, brochures and other printed material.



H H Systems, INC.
Water-to-Water Heat Pumps
ES 200 Data Sheet